

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 430

Date: 28.03.2026

It is certified that an inspection team headed by Ratan Kumar Assistant Engineer  
(Name of Officers with designation) from P.H.E.D (PHED  
Department/Office) inspected the ST. MARY'S SCHOOL, BELDARICHAK, PO.  
KANSARI, DISTT - PATNA, BIHAR, 804451 (Name & Address of the School) on  
NIL Dated 12/02/26 of S.D.L. DANAPUR, PATNA WEST (PHED LAB) has Certified that  
the ST. MARY'S SCHOOL, (Name of School) as safe drinking water facilities for the  
students and members of staff of the institution. School is also maintains the hygienic  
sanitation condition in the school building & the campus as per the norms prescribed by  
the Central/State/U.T Govt.

The Certificate is valid till One year.

Signature with Seal

  
28/3/26  
लोक स्वास्थ्य अवर प्रमोद

Name :

Ratan Kishan Kumar, Patna

Designation :

A.E Patna West  
Patna (PHED)

To ST. MARY'S SCHOOL, BELDARICHAK  
P.O - KANSARI, DIST - PATNA  
BIHAR - 804451  
(Name & Address of the Institution)

Note : The certificate is to be issued by authorized officer / PHED lab / Local Bodies.

Government Of Bihar

Public Health Engineering Department

Water Quality Testing Report

Division Name : Patna West, Patna

Month : Feb'26

Laboratory Name : Sub Divisional Lab, Danapur, Patna West, Patna ,

Sample Collected By J.E.

Sl. No.	Block	Nagar Panchayet	Village	Habitation/Ward no.	Location Details	Latitude	Longitude	Physico - Chemical and Bacteriological Parameters								Date of Sample Tested	Remarks (safe or unsafe)	
								pH	EC	TDS	Total Hardness	Ca	Mg	Cl	Alkalinity.			Date of Sample Received
1	Punpun	Punpun	Beldarichak	Kansari	St. Mary's School			7.24	396	257.4	218	42	27	25	212	07.02.26	09.02.26	
									$\mu\text{mho/cm}$	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l			
									Desirable Limit*	6.5-8.5	500	200	75	30	250	200		
									Permissible Limit* in absence of alternate source	NR	2000	600	200	100	1000	600		

Note: \* (i) Drinking Water Specification Second Revision -IS:10500:2012., (ii) BDL means Below Detection Limit., (iii) NR means no relaxation. (iv) \*\* Shall not be detectable in any 100 ml sample.

*N. S. Singh*  
12/02/26  
Chemist

Sub Divisional Lab, Danapur  
Patna West, Patna

*P. H. Singh*  
12/2/26

Assistant Engineer,  
P.H. Sub Division, Danapur  
Patna West, Patna